

TOWN OF KILLINGWORTH, CONNECTICUT

Proposal Number: 2025-02

PICKLEBALL COURTS AT ROCCO M. REALE FIELD

ADDENDUM 2

2/7/2025

Q: Can you please identify sizes and type of the wire gauge/mesh gauge of fence materials. Also, the size of the line posts/terminals.

A. This information is included in the specs 02790 page 4.

Q. Can you please clarify the asphalt paving binder and surface quantity. Blue Print lists detail as 1.5" and 1" within the specifications detail it states 2" and 1.5" (pages 02790-5-6)

A. Plans are correct at 1.5" under 1".

REMINDER: An optional site visit/pre-bid will be held February 14, 2024 at 9 a.m. Please consult town website for confirmation of time and date.