

ADDENDUM 5

04/08/2025

**REQUEST FOR PROPOSALS FOR  
POINT-OF-ENTRY TREATMENT SYSTEM FOR KILLINGWORTH ELEMENTARY SCHOOL**

Proposal Number: 2025-03

In attendance: Town: E. Couture

RSD17: John Converse, Dennis Reed, Donald Michaud

GZA: Rich Desrosiers

Other: Jimmy Sima

MEETING NOTES:

This meeting is non-mandatory. One potential bidder was in attendance.

- Chase pipe was pointed out as extending under courtyard.
- Need to pull pump out to satisfy DEEP and DPH requirements.
- Question: Can welding be done in the boiler room? Per fire marshal: yes, so long as proper hot work precautions are taken.
- Question: Is there an access point to the boiler room from above? Yes, it is accessible from the courtyard via an access point above the well head.
- Calcite system is upsizing to meet DPH requirements.
- It was noted that there is iron in the water pre-treatment.
- A water storage tank is located in courtyard.
- Existing pipes cross the courtyard. Proposed plans call for piping to be installed above several hallways and the library, the material of piping can be equivalent to proposed spec.
- Could we drill a new well? Permitting times and costs preclude this option at this time. There are also concerns about pulling source contamination further.
- Could a trench outside be utilized to reduce cut through building and connect to crawlspace under original section? Alternatives will be considered.
- What is the current usage of the pumps? 3K – 5K gallons per day, 9 gallons/minute
- What is the UV light treatment for? Stagnant water treatment.
- How are the units exchanged? Full unit exchange – How would equivalent unit be maintained? Inspections occur on a monthly basis per DPH requirements.
- Could acid washed carbon filters be used instead? Equivalent equipment is allowed.
- Orientation of POET system in the '89 wing boiler room? As long as it fits, it was noted that there is sufficient space for the system once an old piece of equipment is removed.

- What plumber is used? The district does not have an on-call plumber.
- Who handles routine inspections? Hungerfords Pump Service
- It was noted by the potential bidder that the water line appears to go between exhaust pipes along the proposed path.

BIDS ARE DUE MONDAY APRIL 14th at 4 PM