

ADDENDUM 8

05/01/2025

**REQUEST FOR PROPOSALS FOR
POINT-OF-ENTRY TREATMENT SYSTEM FOR KILLINGWORTH ELEMENTARY SCHOOL**

Proposal Number: 2025-03

In attendance: Town: E. Couture

RSD 17: D. Reed, J. Converse, D. Michaud

GZA: R. Desrosiers

Other: M. Archer, A. Guillareaut

Meeting Notes:

This meeting was non-mandatory. There was one potential bidder in attendance.

R. Desrosiers began the meeting by noting a discrepancy in the dimensions of the GAC units described in the bidding documents. The drawings are correctly identified as 30" x 72" however the document had previous measurements (16"x65") on one page.

R. Desrosiers also noted that a previous meeting had raised the issue of the control box in the front boiler room as possibly needing replacement. He noted the reasoning for keeping the system as-is due to its current functionality.

The question was raised as to when work was to be completed. The answer is summer of 2025 prior to the opening of school.

The question was raised to who would be handling the responsibility for water testing. During installation would be the responsibility of the operator and contractor, final testing would be the responsibility of the town and GZA.

The status and disposition of the Well #1 water tank was discussed, as well as means of reaching the well. The specific location of the tank was noted to be unclear. Methods of determining precise location were discussed and should be included in the bid.

The current piping through the drop ceiling was analyzed, including the state of the support and materials used in construction. It was noted that there would be substantial work to be done in preparation of the planned construction were new plumbing to follow the existing plumbing.

Discussion of alternative plumbing layouts was had. It was noted that alternatives would be acceptable. Additionally it was noted that the crawlspace under the original building construction could be utilized for plumbing.

Finally, an allowance for the unknown conditions of Well Tank #1, would be allowed relating to: a) the tank's precise location and b) isolating the location of the air vent pipe.

Bids are due by 4:00 pm on May 05, 2025.

Bids will be opened at a Board of Selectman meeting at that time.